

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7272-0028:175 Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detector

**LISTEE:** Notifier, A Pittway Company, One Fire-Lite Place, Northford CT 06472-1653  
Contact: Lawrence Flood (203) 484-1200

**DESIGN:** Model SD-651 photoelectric smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as photoelectric smoke detectors when used in conjunction with listee's listed Models B610LP, B612LP, B614LP, B616LP bases (CSFM Listing No. 7300-0028:173) or System Sensor's Model B401 base (CSFM Listing No. 7300-1209:128) and separately listed compatible control units.

**XLF:** 7272-1209:159

11-10-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**MAY 7, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager